NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

INTEWA Ingenieur-Gesellschaft für Energie- und Wassertechnik GmbH

Facility: Aachen, Germany

AS COMPLYING WITH NSF/ANSI 350 AND ALL APPLICABLE REQUIREMENTS.

PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE

AUTHORIZED TO BEAR THE NSF MARK.







Certification Program Accredited by the Standards Council of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

September 19, 2016 Certificate# C0241945 - 01 Lori Bestervelt

Executive Vice President & CTO

Qui a Bestervea

Requirement and approval results of effluent quality according to NSF/ANSI 350-2014

	Influent range	Requirement effluent		AQUALOOP effluent	
	source water⁴	NSF/ANSI 350-2014		Test results NSF approval	
		Class C		Class C	
		Test Average	Single Sample Maximum	Result Average	Single Sample Maximum
CBOD ₅	130 – 180 mg/l				
BOD ₅		10 mg/l	25 mg/l	5 mg/l	17 mg/l
TSS	80-100 mg/l	10 mg/l	30 mg/l	2 mg/l	7,8 mg/l
turbidity (NTU)	50-100 NTU	2 NTU	5 NTU	0.57 NTU	3.89 NTU
E. coli ²	10 ² -10 ⁴ cfu/100ml	2.2 MPN/100ml	200 MPN/100ml	1.0 MPN/100ml	13.0(MPN/100ml
рН	6.5 – 8.0	6.0 - 9.0	NA ¹	7.38	NA ¹
total phosphorous - P	1.0 -3.0 mg/l				
total Kjeldahl nitrogen-N	3.0 – 5.0 mg/l				
color		MR ³	NA	MR ³	NA
odor		Non offensive	NA	Non offensive	NA
oily film and foam		Non- detectable	Non-detectable	Non- detectable	Non-detectable

¹ NA: not applicable.

Certification NSF/ANSI 350 -2014

Model designations: AQUALOOP System GW 0300 L

AQUALOOP System GW 0600 L AQUALOOP System GW 0900 L AQUALOOP System GW 1200 L AQUALOOP System GW 1500 L AQUALOOP System GW 1800 L

The model designations are tested to meet the requirements in NSF/ANSI 350 corresponding to the designated classification:

NSF/ANSI Standard:	NSF/ANSI 350-2014 Onsite residential and commercial water reuse treatment systems			
Certificate No.:	C0241944 - 01			
Class of greywater input:	Combined, bathing and laundry water effluent			
Class of treated water output:	Class C, multi-family and commercial facilities			
Performance classification, (nominal hydraulic <i>d</i> aily flow)	AQUALOOP System GW 0300 L = 300 Litres / day AQUALOOP System GW 0600 L = 600 Litres / day AQUALOOP System GW 0900 L = 900 Litres / day AQUALOOP System GW 1200 L = 1200 Litres / day AQUALOOP System GW 1500 L = 1500 Litres / day AQUALOOP System GW 1800 L = 1800 Litres / day			
NSF Product and Service Listing:				
http://info.nsf.org/Certified/Wastewater/Listings.asp?TradeName=&Standard=350				

² Calculated as geometric mean.

MR: measured and reported only.

⁴ System for treating bathing and laundry source waters (combined)